



Pye-Barker Fire & Safety
1363 22nd Street N Suite A
St. Petersburg FL 33713
727 327 3244
1264PZ@pyebarkerfs.com

Report Cover Page

SERVICE DATE: 12/29/2025

SERVICE TICKET: ST00849010

BUILDING	STREET	CITY	STATE	ZIP
Outlook Village	6301 58th Street North	Pinellas Park	FL	33781
BUILDING CONTACT	PHONE			
None	7275120604			

Please see the attached reports. If there are any questions, please reach out to the above office.

Download your Report at:

<https://customer.pyebarkerfire.com>

Signed 12/29/2025

Inspector: Richard Myers

Customer did not sign

None

December 29, 2025 02:10 PM

ST00849010 -

Signed 12/29/2025

Building Contact: None
Title:

Service Ticket No. : ST00849010Date : 12/29/2025Frequency : AnnualService Ticket No. : ST00849010Inspection Contract No. : 0003952684

PO No. : _____

Equipment Location : _____

FIRE EXTINGUISHER ITEMIZED

Property :	<u>Outlook Village</u>	Owner :	<u>Outlook Village</u>
Address :	<u>6301 58th Street North</u>	Address :	<u>6301 58th Street North</u>
City :	<u>Pinellas Park</u>	City :	<u>Pinellas Park</u>
State :	<u>FL</u>	State :	<u>FL</u>
Zip :	<u>33781</u>	Zip :	<u>33781</u>
Phone :	<u>7275120604</u>	Phone :	<u>7275120604</u>

DEFICIENCIES

None found at time of inspection.

BUILDING SURVEY**General Questions**

What is the frequency of this service?	<u>Annual</u>
**Are there any other deficiencies?	<u>No</u>

FIRE EXTINGUISHER LIST

Extinguisher or Asset Number	Location	Manufacturer	Mfg Date	Agent Type	Last 6YM	Last Hydro	Unit Results
		Serial Number	Size	Maintenance	Next 6YM	Next Hydro	
	105	Ansul	1996	ABC	12/2025	12/2019	Pass
		NH543960	5	6 Year	12/2037	12/2031	
	103	Ansul	2024	ABC	N/A	N/A	Pass
		I09907272	5	Inspection	12/2030	12/2036	
	103A	Kidde	2023	ABC	N/A	N/A	Pass
		I08967142	2.5	Inspection	N/A	N/A	

Comment: 2.5lb extinguisher doesn't get serviced. Good for 12 years (2035) or used

	Bld 11 1105	Ansul	2003	ABC	12/2025	12/2019	Pass
		ZD581090	5	6 Year	12/2037	12/2031	

• 1363 22nd Street N • St. Petersburg FL • 33713

FIRE EXTINGUISHER LIST

Extinguisher or Asset Number	Location	Manufacturer	Mfg Date	Agent Type	Last 6YM	Last Hydro	Unit Results
		Serial Number	Size	Maintenance	Next 6YM	Next Hydro	
	Bld11 1103	Ansul	2007	ABC	12/2025	12/2019	Pass
		ZD581067	5	6 Year	12/2037	12/2031	
	Bld10 1006	Ansul	2018	ABC	12/2025	N/A	Pass
		E61963497	5	6 Year	12/2037	12/2031	
	Bld10 1003	Ansul	1988	ABC	12/2025	12/2019	Pass
		HU117278	5	6 Year	12/2037	12/2031	
	Bld 9 905	Ansul	2008	ABC	N/A	12/2025	Pass
		VY115246	5	Hydro	12/2031	12/2037	
	Bld9 903	Badger	2015	ABC	12/2021	N/A	Pass
		A33577653	5	Inspection	12/2033	12/2027	
	Bld8 805	Badger	2019	ABC	12/2025	N/A	Pass
		E95415412	5	6 Year	12/2037	12/2031	
	Bld8 803	Buckeye	2003	ABC	12/2016	12/2022	Pass
		VY815381	5	Inspection	12/2028	12/2034	
	Bld7 705	Ansul	2008	ABC	12/2025	12/2019	Pass
		ZD581126	5	6 Year	12/2037	12/2031	
	Bld7 703	Badger	2025	ABC	12/2025	N/A	Pass
		F74363033	5	6 Year	12/2037	12/2031	
	Bld6 605	Ansul	2018	ABC	12/2025	N/A	Pass
		F52457006	5	6 Year	12/2037	12/2031	
	Bld6 603	Amerex	2011	ABC	12/2024	12/2024	Pass
		AR934419	5	Inspection	12/2030	12/2036	
	Bld5 505	Buckeye	2020	ABC	N/A	N/A	Pass
		F65745118	5	Inspection	12/2026	12/2032	
	Bld5 503	Buckeye	1995	ABC	12/2020	12/2016	Pass
		NF00098457	5	Inspection	12/2032	12/2026	
	Bld4 405	Buckeye	2020	ABC	N/A	N/A	Pass
		F92853867	5	Inspection	12/2026	12/2032	

• 1363 22nd Street N • St. Petersburg FL • 33713

FIRE EXTINGUISHER LIST

Extinguisher or Asset Number	Location	Manufacturer	Mfg Date	Agent Type	Last 6YM	Last Hydro	Unit Results
		Serial Number	Size	Maintenance	Next 6YM	Next Hydro	
	Bld4 403	Ansul	2002	ABC	12/2020	12/2020	Pass
		PK926804	5	Inspection	12/2026	12/2032	
	Bld3 305	Ansul	1988	ABC	12/2020	12/2014	Pass
		JB819224	5	Inspection	12/2032	12/2026	
	Bld3 303	Amerex	2000	ABC	12/2018	12/2024	Pass
		SC284938	5	Inspection	12/2030	12/2036	
	Bld2 205	Pyro Chem	2005	ABC	12/2025	12/2019	Pass
		X480671	5	6 Year	12/2037	12/2031	
	Bld2 203	Badger	2019	ABC	12/2025	N/A	Pass
		E95289813	5	6 Year	12/2037	12/2031	


SIGNATURE

This report was reviewed with: Pye-Barker Fire & Safety

Print Name : None Technician : Richard Myers

Signature :

Customer did not sign
None
December 29, 2025 02:10 PM
ST00849010 -

 Signature : 

Date : 12/29/2025 Date : 12/29/2025